



Qualität von Anfang an.

Butterfly Valves Mounting and Operating Manual



© by **END-Armaturen GmbH & Co. KG**

All rights reserved. **END-Armaturen GmbH & Co. KG** claims copyright over this documentation.

This documentation may neither be altered, expanded, reproduced nor passed to third parties without the written agreement of **END-Armaturen GmbH & Co. KG**. This restriction also applies to the corresponding drawings.

END-Armaturen GmbH & Co. KG has the right to change parts of the butterfly valves at any time without prior or direct notice to the client. The contents of this publication are subject to change without notice.

This publication has been written with great care. However, **END-Armaturen GmbH & Co. KG** cannot be held responsible, either for any errors occurring in this publication or for their consequences.

The products are specified by the statements in this documentation; no assurance of the properties is given.

END-Armaturen GmbH & Co. KG

Oberbecksener Straße 78

D-32547 Bad Oeynhausen

Telefon: 05731 / 7900 - 0

Telefax: 05731 / 7900 - 199

Internet: <http://www.end.de>

E-Mail: post@end.de

Edition: 11/02

Contents

1	Foreword	4
2	General Advice	5
2.1	Validity	5
2.2	Inward monitoring	5
2.3	Complaints	5
2.4	Guarantee	5
2.5	Symbols and their signification	6
3	Safety advice	7
3.1	Personal safety	7
3.1.1	Safety advices for mounting	7
3.1.3	Safety advice for adjustment / starting	8
3.1.4	Safety advice for maintaining / repairing	9
3.2	Device safety	10
4	Name-plate	11
5	Butterfly Valve	12
5.1	General	12
5.2	Corresponding use	12
5.3	Operation	12
5.4	Mounting/Disassemble	12
5.4.1	Mounting of the snap-in disc and the handle	13
5.4.2	Mounting of a wafer type butterfly valve	15
5.4.3	Mounting of a LUG type butterfly valve	16
6	Maintenance	17

1 Foreword

Dear customer,
Dear assembler / user,

these operation and installation manuals are intended to give you the knowledge, which is necessary for you to be able to carry out the mounting and adjustment of the butterfly valves rapidly and correctly.



Please read these instructions carefully and pay particular attention to the advice and warning notes.

Only instructed and qualified mechanic should mount, adjust or maintain the butterfly valves.

If you have any questions in relation to the butterfly valves we shall be pleased to answer them. The telephone number will be found on the inside cover of these operation and installation manual.

Yours
END-Armaturen GmbH & Co. KG

2 General Advice

2.1 Validity

This mounting and installation manual is valid for the standard versions of the butterfly valves
TA, WA, WM and their variants

2.2 Inward monitoring

Please check directly after delivery the butterfly valves for any transport damages and deficiencies and with reference to the accompanying delivery note the number of parts.

Do not leave any parts in the package.

2.3 Complaints

Claims for replacement or goods which relate to transport damage can only be considered valid if the delivery company is notified without delay.

In case of returns (because of transport damage / repairs), please make a damage protocol and send the parts back to the manufacturer, if possible in the original packaging.

In case of a return, please mention the following:

- Name and address of the consignee
- Stock-/ ordering-/ article-number
- Description of the defect

2.4 Guarantee

For our butterfly valves we give a guarantee period in accordance with the sales contract. The end of the normal duration of life of the wearing parts represents no defect.

The warrenty and guarantee rules of **END-Armaturen GmbH & Co. KG** are applicable.

Symbols and their Signification

2.5 Symbols and their signification



Paragraphs which are identified with this symbol contain very important advices; this also includes advices for averting health risks. Observe these paragraphs without fail!



Paragraphs which are identified with this symbol contain very important advices, this also includes how to avoid damage to property. Observe these paragraphs without fail!



This symbol indicates paragraphs which contain comments / advices or tips.



This spanner identifies the description of actions which you should carry out.

3 Safety advice

Depending on the technical circumstances and the time under and at which the butterfly valves are mounted, adjusted and commissioned, you must take into account particular safety aspects in each case!

If, for example, a butterfly valve works a slide in an operational chemical plant, the potential hazards of commissioning have another dimension from that when this is only being carried out for test purposes in a „dry“ part of the plant in the assembly room!

Since we do not know the circumstances at the time of the mounting/adjustment/commissioning, you may find advices on hazards in the following descriptions which are not relevant to you.

Please observe (only) the advices which applies to your situation!

3.1 Personal safety

3.1.1 Safety advices for mounting



We wish to point out expressly that the mounting, adjusting and at accessories the pneumatical and electrical installation of the butterfly valves must be carried out by trained specialist personnel having mechanical, pneumatical and electrical knowledge!



Secure that the machine / plant come up to the Machinery Directive after the mounting and installing of the butterfly valves.



Switch off all the devices / machines / plant affected by mounting or repair. If appropriate, isolate the devices / machines / plant from the mains.



Check (for example in chemical plants) whether the switching off of devices / machines / plant will cause potential danger.



If appropriate, in the event of a fault in the butterfly valve (in a plant which is in operation) inform the shift forman / safety engineer or the works manager without delay about the fault, in order, for example, to avoid an outflow / overflow of chemicals or the discharge of gases in good time by means of suitable measures!



Before mounting or repairing, remove the pressure from pneumatic / hydraulic devices / machines / plant.



If necessary, set up warning signs in order to prevent the inadvertent starting up of the devices / machines / plant.



Observe the respective relevant professional safety and accident prevention regulations when carrying out the mounting / repair work.



Check the correct functioning of the safety equipment (for example the emergency push off buttons/ safety valves, etc)!

3.1.3 Safety advice for adjustment / starting



As a result of the starting (pneumatic, electric or by hand) of the butterfly valves the flow of gases, steam, liquids, etc. may be enabled or interrupted! Satisfy yourself that, as a result of the starting or the test adjustment no potential hazards will be produced for the personnel or the environment!



If necessary, set up warning signs in order to prevent the inadvertent starting up or shutting down of the device / machine / plant.!



By ending the adjustment check the correct function and should the occasion arise the position of the butterfly valve.



Check the function of the limit switches (option)!



Check, whether the butterfly valve will be closed totally, if the control signals the appropriate limit stop!



Through suitable measures, prevent links being trapped by moving actuating elements!



Check the right function of all safety devices (for example emergency push off buttons / safety valves)!



Carry out the starting and the adjustments only in accordance with the instructions discribed in this documentation!



Adjusting switches on butterfly valves with options (e.g. actuators, solenoid valves, limit switches) there is the risk that live parts (230 V AC~) can be touched!
Therefore the adjustments must be carried out only by the electrician or a person having adequate training, who is aware of the potential hazard!

3.1.4 Safety advice for maintaining / repairing



Do not carry out any maintenances / repairs if the butterfly valve will be under pressure.

Before disassembling the butterfly valve some essential points should be clarified!

- Will the butterfly valve to be disassembled be replaced by another immediately?
- If appropriate, does the production process of the plant need to be stopped?
- Is it necessary to inform specific personnel about the disassembly?



If necessary, inform the shift foreman/ safety engineer or the manager about the maintenance or repair without delay in order, for example, to avoid an outflow/ overflow of chemicals or a discharge of gases in good time by means of suitable measures!



You have to relieve the pressure in the pipes in which the butterfly valve is mounted.



Switch off pilot pressure and the power supply and relieve the pressure in the pipes.



If necessary set up warning signs in order to prevent

- the inadvertent starting up of the devices/machines/plants in which the butterfly valve is mounted
- the switching on of pilot medium supply, pilot power supply and/or the power supply of actuators and accessories.



In case of defect in the butterfly valve make contact to the supplier. The telephone number will be found on the back cover of these mounting and installation manual.



If you ascertain a damage of the butterfly valve, isolate the device from the mains. Please observe the safety advices.



Do not mount, start or adjust the butterfly valve if itself, the pipes or a mounted actuator will be damaged.



After the maintenance or repair check the right function of the butterfly valve and the tightness of the pipe connections.



Also check the function of the accessories e.g. actuators, limit switches, etc.

3.2 Device safety

The butterfly valves

- are quality products which are produced in accordance to the recognized industrial regulations.
- left the manufacturer`s work in a perfect safety condition.



In order to maintain this condition, as installer / user you must carry out your task in accordance with the description in these instructions, technically correctly and with the greatest possible precision .

We assume, as a trained specialist you are having mechanical and electrical knowledge!



Satisfy yourself that the butterfly vales will only be used within their admissible limiting value (see the technical data) .



The butterfly valves must be used only for a purpose corresponding to their construction!

The butterfly valves must be used within the values specified in the technical data!

The operating of the butterfly valve outside the nominal temperature range could destroy the sealings and the bearings.



The operating of the butterfly valves outside the nominal pressure range could destroy the inner parts and the body.



Do not mount, start or adjust the butterfly valve if itself, the pipes or a mounted actuator will be damaged.



After the maintenance or repair check the right function of the butterfly valve and the tightness of the pipe connections.



Also check the function of the accessories e.g. actuators, limit switches, etc.

The assign accessories for the butterfly valves, e.g. actuator, solenoid valve, limit switch, etc. will be estimate at their potencial ignition sources sseparatly.



If the accessories are electrical parts we will enclose the declaration of conformity of our suppliers. The declaration contains the number of the EC-Type Examination Certificate und the name and the number of the notified body who make out the certificate.

4 Name-plate

The butterfly valves will be provided with a name-plate, which permits a definite identification of the butterfly valve and shows the most important technical data to you. The name-plate should not be displaced or changed.



Fig. 4.1 - Name-plate

Art.Nr.	article number of the butterfly valve
Serie	serial or production number
Betriebsdruck (PS)	max. pressure range of the butterfly valve [bar]
Temperatur (TS)	max. temperature range of the butterfly valve
Größe (DN)	connection size
Prüfdruck (PT)	testing pressure of the butterfly valve
Fluidgruppe	allowed fluid group of the butterfly valve
Herstellung	manufacturing date of the butterfly valve

5 Butterfly Valve

5.1 General

Before you are mount, adjust, start, operate or disassemble a butterfly valve you have to read the



→ Safety advices

If you have not read the safety advices until now, read this important advices now and turn back to this point.

5.2 Corresponding use



Butterfly valves will be used to control and to cut off media flow.

It should only be used clean liquids and gases, on which the material of the butterfly valve will be resistant. It should also be used for pulverised and pasteurised media and pouring goods if it suited to the butterfly valve. Pollution or using outside the nominal pressure range and/or the nominal temperature range should causes damages on the butterfly valve especially on the seals.

5.3 Operation

The butterfly valve will be opened or closed by using a handle or actuator (option). The snap-in handle of a hand actuated butterfly valve have to been snapped out during the operation. The disc has 9 resp. 10 snap-in positions in which the lever could click in, to prevent an inadvertent misplace.



During the closing operation take care that there won't be insert any objects or limbs into the armature. Heavy injuries or damages will be the consequence. If it's necessary you have to install a protective device.

5.4 Mounting/Disassemble

The mechanical installation of the butterfly valves differs by the variants of the body. The wafer type butterfly valve will be squeezed between to flanges and the lug type is able to be mounted directly on flanges.

5.4.1 Mounting of the snap-in disc and the handle



At butterfly valves which will be actuated by hand the snap-in disc and the handle will be enclosed the package. Before installing the butterfly valve you have to mount the handle and the snap-in disc.



Observe the flow direction: the handle should point at the flow direction.



Remove the package and the protective devices (eg. caps and plugs). Take care that there will be no parts of the package or other parts in the armature.



Clean up the pipes in which the butterfly valve will be mounted. Pollution could affect the safety in operation and the duration of life of the butterfly valve.



Avoid stress in case of non align pipes.



The flanges have to be align parallel and centircally and must have carefully worked surfaces.




Fig. 5.1 - Butterfly valves, mounting of the snap-in disc and the handle (Fig.: Art. TA534010)

Butterfly Valves



The butterfly valve will be squeezed between two flanges. The sealing takes place by the sleeve of the butterfly valve other sealing compounds are not allowed. Take care that there won't be insert any rests of sealing compounds or other pollution into the armature.



The flanges would not been welded into the pipes if the armature is mounted. The increasing temperatures will destroy the sleeve of the butterfly valve.



At polluted media we recommend to install the butterfly valve horizontally. In this case the lower disc half have to close in the flow direction.




Fig. 5.2 - Butterfly valves, mounting at pollute media (Fig.: Art. TA534010)

5.4.2 Mounting of a wafer type butterfly valve



In the following description we assume that you have welded the flanges at the end of the pipes and they are cooled down.



Adjust the disc in a not totally closed position so that the disc won't be stand out off the body.



Put the butterfly valve between the flanges. The butterfly have to been insert between the flanges easily so that the sleeve won't be destroyed.



Align the butterfly valve and put fit screws through the borings of the flanges.



Screw nuts onto the screws and tighten them equally slightly and crosswise.



Check wheather the disc of the butterfly valve will be open and close easily. Let the disc a little bit open.



Tighten all the screws crosswise and check the function of the butterfly valve again. Observe the max. torque of the screws.



Check the tightness of all the connections.




Fig. 5.3 - Butterfly valves, mounting of a wafer type butterfly valve (Fig.: Art. TA534010)

Butterfly valves

5.4.3 Mounting of a LUG type butterfly valve



In the following description we assume that you have welded the flanges at the end of the pipes and they are cooled down.



Adjust the disc in a not totally closed position so that the disc won't be stand out off the body.



Put the butterfly valve in front of the flange and tighten the screws slightly and crosswise.



Check wheather the disc of the butterfly valve will be open and close easily. Let the disc a little bit open.



Tighten all the screws crosswise and and check the function of the butterfly valve again. Observe the max. torque moment of the screws.



Check the tightness of all the connections.



You have to install a protective device, to prevent the insertion of any objects or limbs into the butterfly valve.

Install protectivedevices, to prevent a uncontrolled outflow of the media.



Attention: When using the butterfly valve as end piping the nominal working pressure will be decreased.




Fig. 5.4 - Butterfly valves, mounting of a LUG - type butterfly valve (Fig.: Art. TA534010/M)

6 Maintenance

Before you maintain or shut down the butterfly valve you have to read the



→ Safety advice

If you have not read the safety advices until now, read this important advices now and turn back to this point.

On normal accounts the butterfly valve is maintenance free. In periodical turns the controlling of the function and the tightness should happen:



- Check the tightness of stem seals
- Check the tightness of the sleeve
- Check the wear of the sleeve



At a leaky stem seal or sleeve you have to disassemble the butterfly valve and sent it back to the manufacturer.



Don't try to disassemble the sleeve of the butterfly valve by yourself. Heavy injuries or damages could be the consequence.

In case of a defect of the valve make a contact to the supplier. The telephone number will be found on the back of these operation and installation manual.



If you determine that there is a damage to the valve switch off the device/ machine/ plant! However before doing this, it is essential to refer to the

→ Safety advice.



Qualität von Anfang an.

(1) **Declaration in conformity**
(2) **as defined by Pressure-Equipment-Directive 97/23/EG**

(3) Herewith we declare that the supplied articles:

AA, AB, AC, AD, AG, AK, AR, BE, BF, BG, BH, BK, CA, CB, CD, CK, CU, CV, CW, DK, EA, EA, EB, EK, FG, HK, IC, IG, IK, IL, KA, KU, MA, MB, MD, MR, NG, NK, PB, PD, RG, RK, RM, SD, SK, SV, TA, TB, TC, TD, TE, TF, TH, TR, UV, VA, VC, VD, VH, VK, VL, VM, VN, VO, VS, VT, VU, WG, ZA, ZD, ZE, ZF, ZG, ZK, ZP, ZR, SONV, and all variations of these articles

(4) of the company **END-Armaturen GmbH & Co. KG**
D-32547 Bad Oeynhausen
Germany

(5) are in conformity with the regulations of the directive 97/23/EG.

(6) Applied conformity assessment PED: Modul H.

(7) Notified body for conformity assessment PED an Quality-Management-System:




Bureau Veritas S.A.
Paris / Frankreich
Kennzeichen 0062

(8) Applied harmonized standards, in particular:

DIN 3840:1982

**Armaturengehäuse
Festigkeitsberechnung gegen Innendruck**

(9) On behalf


Friedhelm König
Technical Manager



END-Armaturen GmbH & Co. KG
Oberbecksener Str. 78
32547 Bad Oeynhausen · Germany
Telefon: +49 (0)5731 - 7900-0
Telefax: +49 (0)5731 - 7900-80
<http://www.end.de> post@end.de


Bad Oeynhausen, 20. Juli 2004

Michael End
Quality Manager

PRODUCTS

We are developing and producing sophisticated industrial fittings proving every day in the field. This is supported by our fulfilling the requirements of Quality Standards DIN EN ISO 9001. Satisfied partners and success are proving the investment for quality and protection of the environments is worthwhile.



BUREAU
VERITAS



END-ARMATUREN GMBH & CO. KG
OBERBECKSENER STR.78
D-32547 BAD OEYNHAUSEN
POSTFACH (PLZ 32503) 100 341
TELEFON +49 (0) 5731 / 7900-0
TELEFAX +49 (0) 5731 / 7900-199
INTERNET <http://www.end.de>
E-MAIL post@end.de

END-AUTOMATION GMBH & CO. KG
OBERBECKSENER STR.78
D-32547 BAD OEYNHAUSEN
POSTFACH (PLZ 32503) 100 342
TELEFON +49 (0) 5731 / 7901-0
TELEFAX +49 (0) 5731 / 7901-999
INTERNET <http://www.end.de>
E-MAIL post@end.de